

清浄度測定箇所一覧(南館)

3-(4)-4

階	部屋名	清浄度 クラス	室面積 m ²	測定箇所	備考
2F	抗がん剤調整室	10,000	38.48	6	
3F	手術室A	1,000	72.13	6	
	手術室B	1,000	82.70	6	
	手術室C	1,000	83.44	6	
	手術室D	10,000	88.24	6	
	手術室E	1,000	103.40	6	
	手術室F	1,000	45.28	6	
	器材室(1)	100,000	114.33	6	
	器材室(2)	10,000	13.85	2	
	操作室	10,000	30.47	2	
	手術ホール	10,000	247.78	8	
	準備室	10,000	16.43	2	
	展開室	10,000	82.70	4	
	薬剤室	10,000	30.15	2	
	薬剤調整室	10,000	15.09	2	
	スタッフ ステーション	100,000	37.74	3	
	前室	100,000	24.16	1	
	作業室	100,000	9.00	1	
	スタッフ通路 (2)	100,000	64.77	5	
	スタッフ通路 (4)	10,000	6.12	1	
	スタッフ通路 (3)	100,000	41.39	1	
	既滅菌室	10,000	28.26	3	
4F	分娩室(1)	10,000	19.70	2	
	分娩室(2)	10,000	19.41	2	
	LDR(1)	10,000	23.81	2	
	LDR(2)	10,000	23.81	2	
	LDR(3)	10,000	23.51	2	
	新生児室	100,000	40.81	4	
	分娩ホール	100,000	71.80	4	
	陣痛室	10,000	27.11	3	
	MFICU 2431号室	10,000	13.99	2	
	MFICU 2432号室	10,000	15.87	2	
	MFICU 2433号室	10,000	14.75	2	
	MFICU 2434号室	10,000	14.75	2	
	MFICU 2435号室	10,000	14.68	2	
	MFICU 2436号室	10,000	13.85	2	
	MFICUホール	10,000	45.37	2	
	NICU	10,000	147.05	8	
	前室(1)	10,000	10.65	2	
	前室(2) +前室(6)	100,000	26.05	2	
	NICU(個室)	10,000	17.20	2	
	注射室	10,000	11.54	2	
	廊下(2)	10,000	35.13	3	
	検査室	10,000	13.87	2	
	処置室	10,000	8.58	2	
	調乳室	10,000	18.61	2	
	授乳室	10,000	13.07	2	
	リネン室	10,000	5.40	1	
	GCU	10,000	107.79	8	
	沐浴室	10,000	16.11	2	
	スタッフ通路	100,000	23.06	3	
	器材室(NICU)		34.45	4	
5F	HCU+準備室	10,000	215.52	21	
	器材室(1)	10,000	15.75	3	
	2506号室		15.81	1	
	2523号室		15.80	1	